

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 50069  
 Permit No. \_\_\_\_\_  
 Basin 105

1. OWNER Tony Pitts ADDRESS AT WELL LOCATION 28033  
1208 Waterloo Ln. 208 Waterloo Ln.  
Cardonville NV 89410 Cardonville NV 89410

2. LOCATION SE  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec 5 T. 2 S. R. 20 E. Douglas County

PERMIT NO. 25-130-15 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Gravels and Cobbles		0	36	36
Brown clay		36	45	9
Cemented Sands and Gravels		45	92	47
Brown Clay		92	106	14
Large Course Gravels and Sands		106	140	34

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 3/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3 x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 35+ P.S.I.  
 Water temperature Col. °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.H. Pump Company Contractor  
 Address 555 Hwy 50 E #3 Contractor  
Carson City NV 89701

Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael Haek  
 By driller performing actual drilling on site or contractor  
 Date 9-5-95

Date started 9-1 1995  
 Date completed 9-4 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35+</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED  
 95 SEP - 6 AM 10:23  
 STATE ENGINEERS OFFICE