

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 50066
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 7747

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Richard Holbrook ADDRESS AT WELL LOCATION 14 East Purcell
 MAILING ADDRESS 14 East Purcell Yerington, NV 89447
 ADDRESS AT WELL LOCATION 14 East Purcell Yerington, NV 89447

2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 36 T. 13 N S. R. 25 E. Lyon County

PERMIT NO. 18736 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	8	8
Sand & Gravel		8	23	15
Brown Clay w/sand & gravel stringers		23	45	22
Sand & gravel w/some clay		45	106	61
Clay		106	114	8
Sand & gravel		114	220	106
Boulders		220	265	45
Bedrock @ 265 ft.				

8. WELL CONSTRUCTION
 Depth Drilled 270 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 0 Feet 270 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	4205	.250	+2	90

Perforations:
 Type perforation Mill slot & louvered
 Size perforation .125

From full flow 90 feet to 175 feet
 From standard 175 feet to 230 feet
 From DRMS 230 feet to 265 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 265 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Norm °F Quality Good

Date started July 12, 1995
 Date completed July 13, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3000	122'	6

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co Inc. Contractor
 Address P O Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 25, 1995

RECEIVED
 95 AUG 30 AM 10:28
 STATE ENGINEERS OFFICE