

OFFICE USE ONLY  
 Log No. 50076  
 Permit No. I  
 Basin 85

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31854

1. OWNER Roger Canary ADDRESS AT WELL LOCATION 561 Calle de la Plata  
 MAILING ADDRESS 561 Calle de la Plata 561 Calle de la Plata  
Reno, Nevada 89436 Reno, Nevada 89436

2. LOCATION SW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 19 T. 21 N/S R. 21E Washoe County  
 PERMIT NO. 76-371-15 Spanish Springs Ranches  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Black Brown</u>				
<u>White Green Broken</u>				
<u>Fractured Granite</u>		<u>550</u>	<u>650</u>	
<u>T,D, 650</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches 550 Feet 650 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>9.66</u>	<u>.188</u>	<u>510</u>	<u>650</u>

Perforations:  
 Type perforation Factory sawed  
 Size perforation 3/32 x 3  
 From 650 feet to 630 feet  
 From 530 feet to 550 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal In place

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From In place feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level: 440 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 10-5 1995  
 Date completed 10-9 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10+</u>		<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc.  
 Address 1800 1/2 Frazer Avenue  
Sparks, Nevada 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date October 13, 1995