

OFFICE USE ONLY
 Log No. 50078
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 31852

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Chris Benna ADDRESS AT WELL LOCATION Panorama
 MAILING ADDRESS 3025 Mill Street Reno, Nevada
 Reno, NV
 2. LOCATION SW 1/4 NE 1/4 Sec. 6 T. 18 N/S R. 20 E Washoe County
 PERMIT NO. 043-051-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay w/finer sands		0	3	
Green clay		3	12	
Tan clay & cobbles	14	12	22	
Tan clay		22	24	
Coarse brown yellow Green white sand zones & sticky Tan clay		24	143	
Sticky tan clay		143	162	
Coarse sand & gravels Brown white green	165	162	220	
Sticky tan clay		220	224	
Fine vol sands		224	240	
Tan clay		240	254	
Coarse gravels Green brown yellow	225	254	278	
Tan clay		278	289	

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 280 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	188	11-1/2	280

Perforations:
 Type perforation wire wound screen
 Size perforation .030 stainless steel
 From 260 feet to 270 feet
 From 200 feet to 210 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 103 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 280 feet to 103 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE, INC.
 Contractor
 Address 1800-1/2 Frazer Avenue
 Contractor
Sparks, Nevada 89431
 Nevada contractor's license number 35387A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 1, 1995

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>3</u>