

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31861

1. OWNER Mark Faedi ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3530 Voltaire Canyon 3530 Voltaire Canyon
Carson City, Nevada 89704 Carson City, Nevada 89704
 2. LOCATION SE 1/4 NE 1/4 Sec 26 T. 15 N/S R 19 E Carson City County
 PERMIT NO. 007-051-28 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red Clay with Red Brown Vol Rock		0	24	
Black Clay with Green Vol Rock		24	105	
Green Clay with Green Vol Rock		105	325	
Green Vol Rock Hard Fractured		325	565	
Green Brown Vol Rock Fractured		565	775	
775 T.D.				

8. WELL CONSTRUCTION
 Depth Drilled 775 Feet Depth Cased 775 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 55 Feet
8 1/2 Inches 55 Feet 670 Feet
6 1/8 Inches 670 Feet 775 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.52	188	+ 1-1/2	670
5	6.56	188	655	775

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3"
 From 650 feet to 630 feet
 From 755 feet to 735 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 630 feet to 51 feet

9. WATER LEVEL
 Static water level 420 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started October 16, 1995
 Date completed October 31, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	40+		2 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks, Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed Tony Welch
 By driller performing actual drilling on site or contractor
 Date November 6, 1995