

OFFICE USE ONLY
 Log No. 50087
 Permit No. _____
 Basin 091

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 32584

1. OWNER DAVID PUGH ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 2299 3460 Mario Drive
Truckee, CA 96160-2299 Verdi, NV 89523
 2. LOCATION SE 1/4 SE 1/4 Sec 15 T 19N N/S R 18 E Washoe County
 PERMIT NO. 038-682-04 Beli Ranch, Verdi
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------------------------|--------------|------|-----|-----------|
| Brown clay with boulder and gravels | | 0 | 6 | 6 |
| Brown clay | | 6 | 8 | 2 |
| Brown sandy clay | | 8 | 63 | 55 |
| Gray sandy clay | | 63 | 128 | 65 |
| Soft zone | X | 128 | 134 | 6 |
| Gray sandy clay with gravels | | 134 | 179 | 45 |
| Soft zone | X | 179 | 186 | 7 |
| Gray sandy clay | | 186 | 200 | 14 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 100 Feet
 8 5/8 Inches 100 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | | .188 | 0 | 200 |

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 140 feet to 160 feet
 From 175 feet to 195 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 foot Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 200 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date November 27, 1995

Date started 11-20-95, 19____
 Date completed 11-21-95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>30+</u> | | |