WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50093
Permit No.
Basin 101

NOTICE OF INTENT NO. 8348

1. OWNER Dave Akins
MAILING ADDRESS 2160 Rice RD
ADDRESS AT WELL LOCATION ~~Rice~~ 1200 Golden Park FAllon

2. LOCATION NE ¼ SE ¼ Sec. 24 T 19 N/S R. 28 E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 008-322-24 | Subdivision Name Venteracci

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown sand | | 0 | 18 | 18 |
| Brown Clay | | 18 | 21 | 3 |
| Brown Sand | X | 21 | 28 | 7 |
| Grey Sand | | 28 | 50 | 22 |
| Black silt/clay | | 50 | 85 | 35 |
| Grey Sand | | 85 | 88 | 3 |
| Brown clay | X | 88 | 90 | 2 |
| Brown gravel | X | 90 | 93 | 3 |

Date started 8-18, 19 95
Date completed 8-18, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 2 | 1 |

8. WELL CONSTRUCTION
Depth Drilled 93 Feet Depth Cased 98 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 3/4 Inches | | 0 Feet | 50 Feet |
| 6 1/8 Inches | | 50 Feet | 93 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | [illegible] | 0 ft | 98 |
| | | | | |

Perforations:
Type perforation machine cut
Size perforation .030
From 91 feet to 96 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 9' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 0001 °F Quality ok

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp (Contractor)
Address 335 N Broadway (Contractor)
FAllon
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Manzanera (By driller performing actual drilling on site or contractor)
Date 8-18-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627