REPORT NO. 95.54

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 30121
PERMIT NO.
BASIN 085

NOTICE OF INTENT NO. 30837

1. OWNER Karl Caldwell
MAILING ADDRESS 440 Alamosa Dr Sparks, Nv 89436

ADDRESS OF WELL 440 Alamosa Dr
Sparks, Nv 89436

2. WELL LOCATION SE 1/4 SE 1/4 SEC. 12 T 21N R 21 E Washoe COUNTY

PERMIT NO. PARCEL NO 76-290-09 SUBDIVISION NAME Spanish Springs

3. TYPE OF WORK
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [ ] Deepen
- [X] Abandon
- [ ] Other

4. PROPOSED USE
- [X] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [X] Rotary
- [ ] PVC
- [X] Air
- [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

Notes: This borehole was left open without casing or any propective cover. The bore was checked for TD at 212'. Steel encountered, no water in bore. The bore was filled with 3 yards of grout from the top. 7.614 lbs of grout used.

Date Started 9/26/95 Date Completed 9/27/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Lift

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION

Depth Drilled ? Depth Cased none

HOLE DIAMETER (BIT SIZE)

8 1/2	Inches	0	Feet	60	Feet
7 7/8	Inches	60	Feet	212	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
None				

PERFORATIONS:
Type Perforation none Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL

Static Water Level none Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1132

Signed
By driller performing actual drilling on site or contractor

Dated 9/29/95