

OFFICE USE ONLY  
 Log No. 50123  
 Permit No. \_\_\_\_\_  
 Basin Q84

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PERMIT NO. 27263

1. OWNER ELIZABETH GLEDHILL ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5340 Goldenrod Serenity (W of Basque Over Rd/W of  
Reno, Nevada 89511 Reno, Nevada 89510 /Wilcox Ranch Road  
 2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 21N N/S R. 21 E Washoe County  
 PERMIT NO. 076-080-49 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name #130 Palomino Vly

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay, volcanic boulders		1	6	5
Reddish brown clay		6	29	23
Brown clay, volcanic gravels		29	62	33
Light brown clays		62	105	43
Red volcanic rock		105	129	24
Brown volcanic broken rock		129	260	131
Light brown clay		260	297	37
Brown clay		297	355	58
Light brown rusty clay with some sand streaks		355	415	60
Soft zone, gravels	X	415	420	5
Light brown clay		420	440	20
Soft zone, gravles	X	440	445	5
Brown clay		445	450	5

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 450 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	450

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 410 feet to 450 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 450 feet

9. WATER LEVEL  
 Static water level 345 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 10 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]  
 By Driller performing actual drilling on site or contractor  
 Date September 15, 1995

Date started 9-7-95 19\_\_\_\_  
 Date completed 9-12-95 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		