

OFFICE USE ONLY
 Log No. 50128
 Permit No. _____
 Basin. 082

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24350

1. OWNER Pyramical Lake Paiute Tribe / USGS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 333 W. Mye Ln Site #
Carson City NV 89706
 2. LOCATION SW 1/4 SE 1/4 Sec 5 T. 21 N. R. 29 E. Washoe County
 PERMIT NO. M/C 210
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Air Lift

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt		0	6	
Clayey Silt	*	6	12	
Clay		12	14	
Sandy clay	*	14	16	
clayey sand	*	16	37	
Clay		37	43	
sandy clay	*	43	44	
Clay		44	45	

8. WELL CONSTRUCTION
 Depth Drilled 45 Feet Depth Cased 45 Feet
 HOLE DIAMETER (BIT SIZE)
 From 4 Inches To 4 1/2 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>DUC</u>	<u>Sch 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation SPOT
 Size perforation 1.000
 From 35 feet to 45 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 15 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 15 feet to 45 feet

9. WATER LEVEL
 Static water level 15-42 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 12/21 1994
 Date completed 12/21 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Armando P. Robledo Contractor
 Address 333 W. Mye Ln Contractor
Carson City NV 89706
 Nevada contractor's license number _____
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller EP1859
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12/27/95