

Reconditioned by NOI 65430

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 50140
Permit No. 1090A
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26215

1. OWNER Charles R. Schmidt ADDRESS AT WELL LOCATION
MAILING ADDRESS 3816 Patricia Lane 1280 Anselope Rd.
Reno, NV 89512/1114
2. LOCATION SW 1/4 SE 1/4 Sec 28 T 22 N/S R 19 E Washoe County
PERMIT NO. 1090A Red Rock Est. #176
Issued by Water Resources Parcel No. 1090-10 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan Brown Sand		0	28	28
Brown Clay		28	62	34
Rocky Gravel		62	95	33
Gray Sandy Clay		95	107	12
Gray Clay		107	185	78
Broken Red Rock		185	240	55
Solid Gray Granite		240	309	69
		309	420	111

39.738521°N MAD27 D.O.
119.851623°W

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet
HOLE DIAMETER (BIT SIZE)
From 12 Inches To 0 Feet 420 Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 1/8 188 71 420
Perforations:
Type perforation Factory s&T
Size perforation 4
From 390 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 60 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 60 feet to 420 feet

RECEIVED
95 SEP - 5 PM 12:22
STATE ENGINEERS OFFICE

Date started 7-5 1995
Date completed 8-8 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIRLIFT	7		2 HR

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow 7 G.P.M. P.S.I.
Water temperature °F Quality Good
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fredrick Pump & Well Service Contractor
Address P.O. Box 335 Jackson, CA 95642 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0036313
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1940
Signed David J. Glendon By driller performing actual drilling on site or contractor
Date 8-15-95