WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50141
Permit No.
Basin 092A

NOTICE OF INTENT NO. 31855

1. OWNER MARTIN & WENDY PULLMAN
MAILING ADDRESS PO BOX 13847
RENO, NEVADA 89507

ADDRESS AT WELL LOCATION 1265 ANTELOPE VALLEY R
RENO, NEVADA

2. LOCATION SW ¼ NW ¼ Sec. 33 T 22N N/S R19E E. WASHOE County
PERMIT NO. (Issued by Water Resources) 079-420-08 (Parcel No.) Red Rock Estates H-3605 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FINE DG SANDS				
TAN YELLOW BROWN WHITE				
WITH BROWN CLAY			0	128
FIRM BROWN YELLOW				
WHITE SEMI DECOMPOSED				
GRANITE			128	190
STICKY BROWN CLAY			190	235
FINE DG SANDS				
WITH BROWN CLAY				
LAYERS			235	450
GREEN CLAY WITH				
TRACES OF SAND GREEN				
BROWN YELLOW WHITE			450	604
COARSE DG SANDS				
GREEN YELLOW BROWN				
WHITE			604	644
644 TD				

Date started 9-08, 19 95
Date completed 9-13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		3 1/2

8. WELL CONSTRUCTION
Depth Drilled 644 Feet Depth Cased 644 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 inches	0 Feet	55 Feet
8 3/4 inches	55 Feet	420 Feet
8 1/2 inches	420 Feet	644 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1 1/2	644

Perforations:
Type perforation FACTORY SAWED
Size perforation 3/32 x 3"
From 624 feet to 604 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 644 feet to 55 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. PUMP & WELL SERVICE, INC. (Contractor)
Address 1800 1/2 FRAZER AVENUE (Contractor)
SPARKS, NEVADA 89431
Nevada contractor's license number issued by the State Contractor's Board 35387A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date 9-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627