

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24350

1. OWNER Pyramid Lake Paiute Tribe - USFS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 333 W. Nye Ln Carson City NV 89706 46 (east side)  
 2. LOCATION SW 1/4 SW 1/4 Sec 27 T. 22 N. S. R. 24 E. Washoe County  
 PERMIT NO. M/O 9100 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty sand</u>		<u>0</u>	<u>2 1/2</u>	<u>2 1/2</u>
<u>sandy clay</u>		<u>2 1/2</u>	<u>6</u>	<u>3 1/2</u>
<u>gravelly sandy clay</u>	<u>*</u>	<u>6</u>	<u>7</u>	<u>1</u>
<u>sand</u>	<u>*</u>	<u>7</u>	<u>8</u>	<u>1</u>
<u>clay</u>		<u>8</u>	<u>11</u>	<u>3</u>
<u>gravelly clay</u>	<u>*</u>	<u>11</u>	<u>13</u>	<u>2</u>
<u>silty clay</u>	<u>*</u>	<u>13</u>	<u>17</u>	<u>4</u>
<u>clay</u>		<u>17</u>	<u>25</u>	<u>8</u>

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 25  
6 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation slot  
 Size perforation .020  
 From 15 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 15 feet to 25 feet

9. WATER LEVEL  
 Static water level 4.09 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/6, 1995  
 Date completed 1/6, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Armando R. Pablos Contractor  
 Address 333 W. Nye Ln Carson City NV 89706 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller KP1559  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4/28/95