

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24352

1. OWNER Pyramid Lake Paiute Tribe - USFS ADDRESS AT WELL LOCATION Site 42 (west side)
 MAILING ADDRESS 333 W Nye Ln Carson City NV 89706
 2. LOCATION NE 1/4 SE 1/4 Sec 32 T. 22 N. R. 24 E. Washoe County
 PERMIT NO. M/O 9109 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>gravelly silt</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>silt</u>		<u>3</u>	<u>12</u>	<u>9</u>
<u>sandy silt</u>	<u>X</u>	<u>12</u>	<u>14</u>	<u>2</u>
<u>silty sand gravel</u>		<u>14</u>	<u>17</u>	<u>3</u>
<u>silty sand</u>	<u>X</u>	<u>17</u>	<u>25</u>	<u>8</u>

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 Inches 0 Feet 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>5.440</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation slot
 Size perforation .020
 From 20 feet to 25 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 1.0 ft
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 15 feet to 25 feet

9. WATER LEVEL
 Static water level 11.26 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/29, 1995
 Date completed 4/29, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Armando R. Robledo Contractor
 Address 333 W Nye Ln Carson City NV 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources EP1859
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/28/95