

OFFICE USE ONLY  
 Log No. 32161  
 Permit No. 081  
 Basin 081

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24350

1. OWNER Pyramid Lake Paiute Tribe - USGS ADDRESS AT WELL LOCATION Site 1e  
 MAILING ADDRESS 333 W. Nye Ln Carson City, NV 89706  
 2. LOCATION SW 1/4 NE 1/4 Sec. 26 T. 23 N/S R. 23 E Washoe County  
 PERMIT NO. M/O-910a Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravelly sand		0	2-1/2	2-1/2
sand (coarse)		2-1/2	3-1/2	1
gravelly sand.	X	3-1/2	8	4-1/2
sandy, silty, sand	X	8	10	2
sandy, gravelly sand	X	10	20	10

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6 Inches 0 Feet 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation slot  
 Size perforation .020  
 From 15 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 15 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 15 feet to 20 feet

9. WATER LEVEL  
 Static water level 6.29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12/9, 1994  
 Date completed 12/9, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Armando P. Robledo Contractor  
 Address 333 W. Nye Ln Carson City, NV 89706 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, on-site driller EP1859  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Apr 20, 1995