WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

MW-2

OFFICE USE ONLY
Log No. 50168
Permit No.
Basin 0419

NOTICE OF INTENT No. 28658

1. OWNER D.J. Warren
MAILING ADDRESS 5705 South Desert Marigold Drive
Gold Canyon, AZ 85219

ADDRESS AT WELL LOCATION Sixth street and Idaho to 642 Idaho
Elko, NV

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 34 N R. 55 E Elko County
PERMIT NO. MO-979 Issued by Water Resources
01-27402-6 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay and Silt		0	8	8
Silt and gravel		8	18	10
Silt, gravel and cobbles	19.3	18	28.5	10.51

Date started 8-30, 1995
Date completed 8-30, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
not completed		
monitor well only		

8. WELL CONSTRUCTION
Depth Drilled 28.5 Feet Depth Cased 28.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6¼ Inches	0 Feet	28.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40 PVC	0	18.5

Perforations:
Type perforation factory slotted
Size perforation .010
From 18.5 feet to 28.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 15'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No 16/40 sand
From 15 feet to 28.5 feet

9. WATER LEVEL
Static water level 19.33 feet below land surface
Artesian flow N/A G.P.M. 0 P.S.I.
Water temperature N/A °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wilburn L. Franklin Contractor
Address 1707 S. 4490 W. Contractor
SLC, UT 84010

Nevada contractor's license number issued by the State Contractor's Board 5830

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1970

Signed Wilburn L. Franklin
By driller performing actual drilling on site or contractor

Date 9-1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627