WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 5617
Permit No.
Basin 077

NOTICE OF INTENT No. 32579

1. OWNER MR. & MRS. FEINBERG
MAILING ADDRESS 995 Drake
Sparks, NV 89434

ADDRESS AT WELL LOCATION 5020 Pleasant View Drive
Sparks, NV 89434

2. LOCATION SE ¼ NW ¼ Sec. 1 T 19N N/S R ~~19~~ 20 E Washoe County
PERMIT NO. (Issued by Water Resources) | 030-202-03 (Parcel No.) | East Sparks (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown clay with boulders		3	51	48
Reddish brown volcanic rock		51	61	10
Broken fracture volcanic rock		61	127	66
Brown volcanic rock		127	158	31
Reddish brown volcanic rock		158	166	8
Grey volcanic rock		166	189	23
Multi-color volcanic rock		189	241	52
grey volcanic rock		241	345	104
fracture rock(app 5GPM)	X	345	351	6
Grey volcanic rock		351	405	54
Fracture rock	X	405	412	7
Grey volcanic rock		412	425	13

Date started 11-13-95, 19
Date completed 11-17-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		

8. WELL CONSTRUCTION
Depth Drilled 425 Feet Depth Cased 425 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	425 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	425

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 338 feet to 358 feet
From 378 feet to 418 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 425 feet

9. WATER LEVEL
Static water level 321 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 24, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627