

OFFICE USE ONLY
 Log No. _____
 Permit No. _____
 Basin. _____
 NOTICE OF INTENT NO. 31864

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dale & Lisa Brise ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2265 Rabbit Drive 2265 Rabbit Drive
Carson City, Nevada 89703 Carson City, Nevada 89703
 2. LOCATION SW 1/4 NE 1/4 Sec. 31 T. 17N N/S R. 20 East Washoe County
 PERMIT NO. 50-387-07
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Orange, Tan, Brown D.G. Sand		0	27	
Fine Green & White D.G. w/Green Clay Layers		27	88	
Course Green & White D.G. Sands		88	118	
Green White Semi Decomposed Granite	X	118	190	
T.D. 190				

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 190 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 120 Feet
8-1/2 Inches 120 Feet 190 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	190

Perforations:
 Type perforation Well Screen
 Size perforation .020
 From 180 feet to 160 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 101 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 190 feet to 101 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started November 16 1995
 Date completed November 18 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	10		1-1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks, Nevada 89431
 Nevada contractor's license number 35387-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date November 27, 1995