REPORT NO. 95.45

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 50201
PERMIT NO.
BASIN 089

NOTICE OF INTENT NO. 30827

OWNER Roger Primm

MAILING ADDRESS 2445 Faretto Ln Reno, Nv 89511

ADDRESS OF WELL 5370 Franktown Rd
Carson City, Nv

2. WELL LOCATION SW 1/4 SW 1/4 SEC. 10 T 16N R 19 E Washoe COUNTY

PERMIT NO. ____ PARCEL NO 55-060-35 SUBDIVISION NAME ____

3. TYPE OF WORK

[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE

[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE

[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Calechee clay		0	21	21
Brown DG		21	26	5
Salt & pepper granite		26	109	83
Hard, fractured granite		109	113	4
Softer, light brown DG		113	121	8
Hard, fractured granite		121	128	7
Smooth hard granite, brown/tan quart		128	270	142
Clay & sand		270	287	17
Hard granite, some fractures		287	345	58
Soft DG		345	350	5
Hard granite, some fractures		350	460	110
Dark green, black & white granite		460	530	70
ard, dark green granite		530	600	70

RECEIVED 95 SEP 14 AM 11:23 STATE ENGINEERS OFFICE

Notes: Bottom of borehole full of native material

Date Started 8/11/95 Date Completed 8/27/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [X] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	60	148	

8. WELL CONSTRUCTION

Depth Drilled 598 Depth Cased 500

HOLE DIAMETER (BIT SIZE)

13 1/3 Inches 0 Feet 350 Feet
10 Inches 350 Feet 400 Feet
8 Inches 400 Feet 600 Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
8 5/8	16.94	.188	+1	400
6 5/8	12.92	.188	280	500

PERFORATIONS:

Type Perforation factory Size Perforation 3/32 x 3
From 320 Feet to 340 Feet
From 360 Feet to 380 Feet
From 440 Feet to 500 Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 400 Feet

9. WATER LEVEL

Static Water Level 57 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature ____ F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1132/1981

Signed Roger Primm
By driller performing actual drilling on site or contractor

Dated 9/12/95