WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50202
Permit No.
Basin 101

NOTICE OF INTENT NO. 32959

1. OWNER Michael Casey
MAILING ADDRESS 1550 Allen Rd.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION
14440 Violets Rd.
Fallon, NV. 89406

2. LOCATION ~~NE~~ NW ¼ ~~NW~~ SE ¼ Sec. 25 T. 19 N/S R. 26 E. Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 007-071-67 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Brown Clay		10	25	15
Sand		25	35	10
Clay		35	44	9
Sand		44	95	51
Reddish Clay		95	110	15
Sand		110	125	15
Clay		125	135	10
Sandy Clay		135	155	20
Sand	XX	155	170	15
Brown Clay		170	175	5

RECEIVED
95 SEP -6 AM 10:46
STATE ENGINEER'S OFFICE

Date started July 25, 19 95
Date completed JUly 25, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	175 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	175

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft.
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne [illegible] (By driller performing actual drilling on site or contractor)
Date Aug 24, 95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627