

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION 5770 EAGLE ST. LOT 5 BK D  
MAILING ADDRESS 2008 3rd St. Sparks, NV 89431  
2. LOCATION SE 1/4 NE 1/4 Sec 7 T. 34 S. R. 38 E. PERSHING County BURNS ACRES  
PERMIT NO. 09-431-05 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY/SAND</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>SAND/gravel</u>		<u>20</u>	<u>30</u>	<u>10</u>
<u>Emerged Layer</u>		<u>30</u>	<u>60</u>	<u>30</u>
<u>SAND/gravel</u>		<u>60</u>	<u>80</u>	<u>20</u>
<u>SAND/gravel</u>	<u>X</u>	<u>80</u>	<u>110</u>	<u>30</u>

8. WELL CONSTRUCTION  
Depth Drilled 110 Feet Depth Cased 110 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 110 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>0.50</u>	<u>12</u>	<u>188</u>	<u>0</u>	<u>110</u>

Perforations:  
Type perforation Factory Cuts  
Size perforation 3/32  
From 40 feet to 110 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 53  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 53 feet to 110 feet

9. WATER LEVEL  
Static water level 50 feet below land surface  
Artesian flow NO G.P.M. N/A P.S.I.  
Water temperature COOL °F Quality Good

Date started 11-21 1995  
Date completed 11-22 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>N/A</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name FRED ANDERSON Contractor  
Address 10760 GRASS VALLEY WINNEMUCA, NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board: 0021467  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1375  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 12-5-95

RECEIVED  
95 DEC +5 AM 11 56  
STATE ENGINEERS OFFICE