WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50208
Permit No.
Basin 071

NOTICE OF INTENT NO. 32390

1. OWNER Cliff Buens
MAILING ADDRESS 2008 3rd St.
Sparks, NV 89431

ADDRESS AT WELL LOCATION Corner Wrens Hawk
Blk B - Lot 10

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 34 N/S R. 38 E. Pershing County
Buens Acres

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay/sand | | 0 | 20 | 20 |
| Sand/gravel | | 20 | 30 | 10 |
| Fingered layers | | 30 | 60 | 30 |
| Sand/gravel | | 60 | 80 | 20 |
| Sand/gravel | X | 80 | 110 | 30 |

RECEIVED 95 DEC 5 AM 11:56 STATE ENGINEER'S OFFICE

Date started 12-1, 1995
Date completed 12-1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20+ | N/A | 1 hr. |

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 110 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12 | .188 | 0 | 110 |

Perforations:
Type perforation Factory Cuts
Size perforation 3/32
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 110 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FRED Anderson Contractor
Address 10760 Grassy Way Contractor
Winnemucca, NV
Nevada contractor's license number issued by the State Contractor's Board. 0021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed By driller performing actual drilling on site or contractor
Date 12-5-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627