WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58211
Permit No.
Basin 79

NOTICE OF INTENT NO. 16441

1. OWNER Ice Ryerson
MAILING ADDRESS 595 Sage Elko Nev. 89801
ADDRESS AT WELL LOCATION 28 North 48 west 1 mile south Hercules Gap Ely Nev.

2. LOCATION S/W ¼ N/W ¼ Sec. 15 T. 17 N R. 63 E White Pine County
PERMIT NO. — Issued by Water Resources | Parcel No. 69 | Subdivision Name Cross Timbers

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 5 | 5 |
| Sand - Boulders | | 5 | 47 | 42 |
| Hard Rock | | 47 | 96 | 49 |
| Coarse Gravel | X | 96 | 110 | 14 |
| Hard Rock | | 110 | 130 | 20 |
| Coarse Gravel | X | 130 | 140 | 10 |
| Hard Rock | | 140 | 143 | 3 |
| TD 143 | | | | |

RECEIVED OCT 19 1995 DCNR/DWR LAS VEGAS OFFICE

Date started 9-7-95, 19
Date completed 9-9-95, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Bailer | 14 | 2 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 143 Feet Depth Cased 143 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 143 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | — | .188 | 0 | 143 |
| | | | | |
| | | | | |

Perforations:
Type perforation torch cut
Size perforation 1/8" x 6"
From 103 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 143 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address P.O. Box 54 Elko Nev. 89801 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 9-13-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627