

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32572

1. OWNER JERRY PONCIA ADDRESS AT WELL LOCATION 595 Riverdale Cir  
 MAILING ADDRESS 231 So. Virginia Street Verdi, Nevada 89439  
Reno, Nevada 89501  
 2. LOCATION SW 1/4 W 1/2 1/4 Sec 8 T 19N N/S R 18 E Washoe County  
 PERMIT NO. 038-691-03 Donner Trail Sub Division  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Static water level @191, Yield 1 GPM				
Clean bottom in well.				
Gray clay		275	312	37
Soft zone, NO WATER		312	316	4
Gray clay		316	317	1
Green clay		317	322	5
Gray clay		322	338	16
Soft zone	X	338	348	10

8. WELL CONSTRUCTION  
 Depth Drilled 348 Feet Depth Cased 348 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches 275 Feet 348 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	348

 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 273 feet to 333 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal deepening  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 260 feet to 348 feet

Date started 10-2-95, 19\_\_\_\_\_  
 Date completed 10-6-95, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8.2</u>		

9. WATER LEVEL  
 Static water level 161 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 8.2 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date October 12, 1995