

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28875

1. OWNER Eric Williams ADDRESS AT WELL LOCATION 5 miles north of Ely  
MAILING ADDRESS 604 Murry Street  
Ely, Nv 89301

2. LOCATION SE 1/4 SW 1/4 Sec. 14 T. 17 N/S.R. 63 E. White Pine County  
PERMIT NO. 05-581-64 Parcel No. Lot 6 Subdivision Name Cross Timbers  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Gravel		5	25	20
Clay & Gravel		25	55	30
Water Bearing Gravel	x	55	70	15
Clay & Gravel		70	95	25
Water Bearing Gravel	x	95	115	20
Clay & Gravel		115	145	30
Water Bearing Sand & Gravel	x	145	150	5
Clay		150	160	10

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 0 Feet 160 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:  
Type perforation Factory  
Size perforation 1/8" x 2 1/2" 6 rows  
From 60 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 160 feet

9. WATER LEVEL  
Static water level 55 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Colc °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Christiansen Drilling, Inc. Contractor  
Address 557 Ely Avenue Contractor  
Ely, NV 89301  
Nevada contractor's license number issued by the State Contractor's Board 14790  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
Signed Juvel D. Christiansen  
By driller performing actual drilling on site or contractor  
Date October 11, 1995

Date started October 5, 19 95  
Date completed October 7, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>150</u>	<u>95</u>	<u>1</u>

RECEIVED  
95 OCT 23 AM 11:19  
STATE ENGINEERS OFFICE