WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50224
Permit No.
Basin 179
NOTICE OF INTENT No. 22469

1. OWNER Boyd J. or Betty Jo Cole
MAILING ADDRESS 1668 West 1920 North Layton Ut. 84041
ADDRESS AT WELL LOCATION Lot 107 Lackawana rd.

2. LOCATION NE ¼ NE ¼ Sec. 21 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) | 5-C01-06 (Parcel No.) | Cross timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	14	
gravel conglomerate		14	20	
Sandy Clay		20	25	
gravel con.		25	40	
Clay con		40	45	
gravel con		45	47	
Clay con		47	56	
gravel con		56	61	
CL		61	64	
gravel con.		64	75	
gravel clay con		75	85	
Clay con		85	97	
gravel con		97	106	
Clay		106	113	
gravel con	water	113	126	13
Clay con		126	140	
gravel	water	140	147	
Clay		147	149.5	
gravel	water	149.5	150.5	
Sandy Clay		150.5	158	
gravel	water	158	161	
Sandy Clay		161	164	
gravel	water	164	165	

Date started August 28-95, 19 95
Date completed Sept 25, 19 95

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	5	1 hr

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	165 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.1	.188	-1	165

Perforations:
Type perforation mill
Size perforation 5/8 x 2.5" x 6 row
From feet to feet
From 125 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 113 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R. Maynard (Contractor)
Address PoBox 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orson Maynard (By driller performing actual drilling on site or contractor)
Date Oct 9-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627