

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28/31

1. OWNER Roger Mitchell ADDRESS AT WELL LOCATION 2570 Snyder Carson City NV. 89701  
 MAILING ADDRESS 2570 Snyder Carson City NV. 89701  
 2. LOCATION SE 1/4 SW 1/4 Sec 3 T 14 S R 20 E Carson County  
 PERMIT NO. 10-491-14 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Course DG Sands (Firm)</u>		<u>2</u>	<u>87</u>	<u>85</u>
		<u>87</u>	<u>115</u>	<u>28</u>
<u>Soft DG Sands</u>	<u>xxx</u>	<u>115</u>	<u>130</u>	<u>15</u>
<u>Carrying Little Water</u>				
<u>Very Sandy</u>				
<u>Hard Broken DG</u>	<u>xxx</u>	<u>130</u>	<u>160</u>	<u>30</u>
<u>Gravels</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation M.I. Slot  
 Size perforation 3 X 3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature Cold °F Quality Good

Date started 10-12, 1995  
 Date completed 10-13, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>20</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.H. Pump Co. Contractor  
 Address 555 Hwy 50 E #3 Carson City NV. 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Haek  
 By driller performing actual drilling on site or contractor  
 Date 9-13-95