

OFFICE USE ONLY  
Log No. 50236  
Permit No. \_\_\_\_\_  
Basin. (103)

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28130

1. OWNER Dave Crist ADDRESS AT WELL LOCATION 140 Comstock DR Dayton NV 89403  
MAILING ADDRESS Dayton NV 89403  
2. LOCATION SE 1/4 SE 1/4 Sec. 36 T 17 S R 22 E Lyon County  
PERMIT NO. 19-161-05 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Blow Sands</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Coarse Sands and Gravels</u>		<u>3</u>	<u>36</u>	<u>33</u>
<u>Course Sands</u>		<u>36</u>	<u>85</u>	<u>49</u>
<u>Small Layers of Brown clay</u>				
<u>Brown Clay Zone</u>		<u>85</u>	<u>130</u>	<u>45</u>
<u>Hard Broken Gravels</u>		<u>130</u>	<u>160</u>	<u>30</u>

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>1 1/4</u>	<u>0</u>	<u>50</u>	<u>Feet</u>
<u>1 7/8</u>	<u>50</u>	<u>160</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:

Type perforation M.H. Slot  
Size perforation 3 x 3/32  
From 140 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 160 feet

9. WATER LEVEL

Static water level 9.5 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.H. Pump Company Contractor  
Address 5551 Hwy 50 E #3 Contractor  
Carson City NV 89701  
Nevada contractor's license number issued by the State Contractor's Board. 31839  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1905  
Signed Michael J. Beck  
By driller performing actual drilling on site or contractor  
Date 10-4-95

Date started 10-2, 1995  
Date completed 10-4, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>20</u>	<u>4 HRS</u>

RECEIVED  
95 OCT -9 AM 9:38  
STATE ENGINEERS OFFICE