WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50240
Permit No.
Basin 101

NOTICE OF INTENT NO. 32940

1. OWNER Manuel Leal
MAILING ADDRESS 941 Tiffany Dr.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION 6355 Lakeview Dr.
Fallon, NV. 89406

2. LOCATION NE ¼ SE ¼ Sec. 18 T 19 N/S R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) Parcel No. 8-113-27 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Gravel | | 0 | 12 | 12 |
| Coarse Sand & Gravel | | 12 | 18 | 6 |
| Coarse Sand & Gravel | XXX | 18 | 28 | 10 |
| Clay | | 28 | 30 | 2 |

Date started Sept. 15, 1995
Date completed Sept. 15, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8-1/2 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 30 |

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 28 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 25ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 30 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265- (Contractor)
FALLON, NV. 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1758

Signed (By driller performing actual drilling on site or contractor)
Date 10/3/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627