

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28877
2 1/2 miles South of Ely

1. OWNER Gary Sprouse ADDRESS AT WELL LOCATION
 MAILING ADDRESS HC 66, Box 56A
Neola, Utah 84053

2. LOCATION NE 1/4 NE 1/4 Sec 35 T 16 N&S R. 63 E White Pine County
 PERMIT NO. WELL No. 1 2B
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	40	40
Clay & Gravel		40	130	90
Gravel		130	135	5
Clay		135	165	30
Clay & Gravel		165	175	10
Clay		175	205	30
Clay & Gravel		205	245	40
Clay		245	270	25
Sand & Gravel With Clay Seams	x	270	285	15
Clay		285	320	35
Sand & Gravel With clay Seams	x	320	365	45
Clay		365	370	5
Sand & Gravel With Clay Seams	x	370	380	10
Clay		380	400	20

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	400

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 300 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 265 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Address 557 Ely Avenue
Ely, Nv 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 641
 Division of Water Resources, the on-site driller.
 Signed Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date November 2, 1995

Date started October 16, 1995
 Date completed October 21, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>21</u>	<u>125</u>	<u>1 1/2</u>

RECEIVED
 55 NOV - 7 PM 2:23
 STATE ENGINEERS OFFICE