

OFFICE USE ONLY  
 Log No. 50251  
 Permit No. 08  
 Basin 08  
 NOTICE OF INTENT NO. 31868

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jim Wallace ADDRESS AT WELL LOCATION 2261 Lousetown Rd.  
 MAILING ADDRESS P.O. Box 5848 Reno, Nevada 89511  
Incline Village, Nevada 89450  
 2. LOCATION SW 1/4 NW 1/4 Sec. 33 T. 18 N/S R. 21 E. Story County  
 PERMIT NO. 03-042-24 Virginia City Highlands Ranches Estates  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	
Brown Clay		2	12	
Blue, Gray, Volcanic Rock		12	26	
Brown Volcanic Rock Soft Zone		26	32	
Blue, White, Brown Volcanic Rock		32	52	
Gray Clay (sticky)		52	194	
Blue, Green, White Volcanic Rock				
Highly Fractured	X	194	204	
T.D. 204				

8. WELL CONSTRUCTION  
 Depth Drilled 204 Feet Depth Cased 204 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10-5/8 Inches 0 Feet 51 Feet  
8-1/2 Inches 51 Feet 204 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1	204

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 204 feet to 184 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 204 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Good

Date started December 1, 1995  
 Date completed December 1, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service, Inc. Contractor  
 Address 1800 1/2 Frazer Ave. Contractor  
Sparks, Nevada 89431  
 Nevada contractor's license number 35387-A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1509  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date December 4, 1995