

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31863

1. OWNER Sonny Hutchins
 MAILING ADDRESS 1465 E. Peckham Ln. #76
Reno, Nevada 89502
 ADDRESS AT WELL LOCATION 1864 Lousetown Rd.
Reno, Nevada 89511
 2. LOCATION NW 1/4 NW 1/4 Sec. 4 T. 17 N. S. R. 21 Story County
 PERMIT NO. 03-122-36 Virginia City Highlands Ranches Estates Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	
Brown Clay		3	22	
Tan & Red Clay w/ some volcanic rock		22	28	
Muti Colored Volcanic Rock w/some Tan Clay		28	34	
Tan Clay w/some Volcanic Rock		34	64	
Multi Colored Volcanic Rock (Soft)		64	84	
Blue, Gray, Volcanic Rock Fractured		84	96	
Blue, Gray, & Brown Volcanic Rock	X	96	120	
T.D. 120				

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 52 Feet
8-1/2 Inches 52 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1	120

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 120 feet


9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started November 30, 1995
 Date completed November 30, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P Pump & Well Service, Inc.
 Address 1800 1/2 Frazer Ave.
Sparks, Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 4, 1995



DO NOT WRITE ON THIS SIDE
PRINT OR TYPE NAME
NAME - WILL BE PRINTED
CITY - WILL BE PRINTED
STATE - WILL BE PRINTED

WILLIAM WALTERS
WILLIAM WALTERS
WILLIAM WALTERS

OWNER
MAILING ADDRESS
CITY
STATE
ZIP

WALTERS
WALTERS
WALTERS

Handwritten signature

OFFICE USE ONLY
 Log No. 50252
 Permit No. _____
 Basin. 0831

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31863

1. OWNER Sonny Hutchins ADDRESS AT WELL LOCATION 1864 Lousetown Rd.
 MAILING ADDRESS 1465 E. Peckham Ln. #76 Reno, Nevada 89511
 2. LOCATION NW 1/4 NW 1/4 Sec 4 T. 17 N. R. 21 E. Story County Virginia City Highlands Ranches Estates
 PERMIT NO. 03-122-36 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	
Brown Clay		3	22	
Tan & Red Clay w/ some volcanic rock		22	28	
Muti Colored Volcanic Rock w/some Tan Clay		28	34	
Tan Clay w/some Volcanic Rock		34	64	
Multi Colored Volcanic Rock (Soft)		64	84	
Blue, Gray, Volcanic Rock Fractured		84	96	
Blue, Gray, & Brown Volcanic Rocks	X	96	120	

T.D. 120
 RECORDED
 23 DEC - 1 11:20 AM
 WELLS DIVISION

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 52 Feet
8-1/2 Inches 52 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1	120

Perforations:
 Type perforation Factory Sawed
 Size perforation 3/32 x 3
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 51 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 51 feet to 120 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started November 30, 1995
 Date completed November 30, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P Pump & Well Service, Inc.
 Address 1800 1/2 Frazer Ave.
Sparks, Nevada 89431
 Nevada contractor's license number 35387-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 4, 1995