

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30622

1. Consultant: PARSONS ENGINEERING SCIENCE, INC Client: _____
 OWNER: _____ ADDRESS AT WELL LOCATION: GREYHOUND LINES, INC.
 MAILING ADDRESS: 290 Elwood Davis Road, Ste 312 460 West 2nd Street (Terminal)
Liverpool, New York 13088 Reno, NV

2. LOCATION: DA NE 1/4 SE 1/4 Sec 11 T 19N N/S R 19 E Washoe County
 PERMIT NO. R-272 M/O-175 MW3 011-024-18 Downtown Reno, NV
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MONITOR WELL ABANDONMENT:				
Static water level @ <u>18.3 feet</u>				
Total depth @ <u>23.10 feet</u>				
Equipment used:				
<u>F-800 water truck & F-450 support truck & 3 man crew</u>				
<u>Walnut Grove high pressure grout pump & mixer</u>				
<u>20 feet x 1 1/2" dia tremie pipe</u>				
Materials used:				
<u>6 sacks of Portland Cement Type II</u>				
<u>1. Measure static water level & total depth</u>				
<u>2. Glue threaded adapter to existing casing</u>				
<u>3. Set tremie pipe to bottom of casing</u>				
<u>4. Pump neat cement from bottom to surface (4 sacks)</u>				
<u>5. Pull tremie, fill casing & attach from cement pump directly to casing.</u>				
<u>6. Pump cement @ 100 to 125 PSI squeezing cement through perforations into the surrounding formations. (2 sacks) When pressure increases, discontinue pumping</u>				
<u>7. Remove traffic cover, replace section of sidewalk</u>				
Location: <u>E of terminal bldg. in sidewalk to Stevenson Street</u>				
Date started: <u>11-15-95</u> , 19____				
Date completed: <u>11-15-95</u> , 19____				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____	To _____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____

Size perforation _____

From	feet to	feet
From _____	_____	_____

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No

From _____ feet to _____ feet

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level _____ feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: WAYNE DRILLING, INC. Contractor

Address: P.O. BOX 12370 Contractor

RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board: 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908

Signed: [Signature] By driller performing actual drilling on site or contractor

Date: November 21, 1995