

OFFICE USE ONLY  
 Log No. 50288  
 Permit No. 087  
 Basin.

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30622

Consultant: PARSONS ENGINEERING SCIENCE, INC. Client: GREYHOUND LINES, INC.  
 1. OWNER: 290 Elwood Davis Road, Ste 312 ADDRESS AT WELL LOCATION: 460 West 2nd Street (Terminal)  
 MAILING ADDRESS: Liverpool, New York 13088 Reno, Nevada  
 2. LOCATION DA NE 1/4 SE 1/4 Sec. 11 T. 19N N/S R. 19E E Washoe County  
 PERMIT NO. R-272 M/O-175 MW1 011-024-18 Downtown Reno NV  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other.....  Municipal/Industrial  Monitor  Stock  Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MONITOR WELL AVBANDONMENT				
Static waterlevel @18.3 feet				
Total depth @23.10 feet				
Equipment used:				
F-800 water truck, F-450 Support truck				
3 man crew				
Walnut Grove High pressure grout pump & mixer				
20 feet x 1 1/4" dia tremie pipe				
Materials used:				
6 sacks of Portland Cement Type II				
1. Measure static water level & total depth				
2. Glue threaded adapter to existing casing				
3. Set tremie pipe to bottom of casing				
4. Pump neat cement from bottom to surface (4sks)				
5. Pull tremie, fill casing & attach from cement pump directly to casing				
6. Pump cement @100 to 125 PSI squeezing cement through perforations into the surrounding formation. (2 sacks). When pressure increases, discontinue pumping				
7. Remove traffic cover, patch asphalt.				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

.....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....

Size perforation.....

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:

Depth of Seal.....  Neat Cement

Placement Method:  Pumped  Cement Grout

Poured  Concrete Grout

Gravel Packed:  Yes  No

From.....feet to.....feet

Location: NE corner of landscaping, N of First Street  
 Date started..... 11-15-95..... 19.....  
 Date completed..... 11-15-95..... 19.....

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level.....feet below land surface

Artesian flow.....G.P.M.....P.S.I.

Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name..... WAYNE DRILLING, INC. Contractor

Address..... P.O. BOX 12370 Contractor

RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board..... 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 908

Signed..... By driller performing actual drilling on site or contractor

Date..... November 21, 1995