

Log No. 50291
 Permit No. _____
 Basin 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 30622
 GREYHOUND LINES, INC.

Consultant: PARSONS ENGINEERING SCIENCE, INC. Client: _____
 1. OWNER: _____ ADDRESS AT WELL LOCATION: _____
 MAILING ADDRESS: 290 Elwood Davis Street, Ste 312 460 West 2nd Street
Liverpool, New York 13088 Reno, Nevada
 2. LOCATION: DA NE 1/4 SE 1/4 Sec 11 T. 19N N/S R 19 E Washoe County
 PERMIT NO. R-272 M/O-175-A MW9 011-024-18 Downtown Reno, NV
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MONITOR WELL ABANDONMENT:				
Static water level @22.9 feet				
Total depth @28.0 feet				
Equipment used:				
F-800 water truck, F-450 support truck and 3 man crew				
Walnut Grove high pressure grout pump & mixer				
27 feet x 1 1/2" dia. tremie pipe				
Materials used:				
7 sack of Portland Cement Type II				
1. Measure static water level & total depth				
2. Glue threaded adapter to existing casing.				
3. Set tremie pipe to bottom of casing				
4. Pump neat cement from bottom to surface (6 sacks)				
5. Pull tremie, fill casing & attach from cement pump directly to casing.				
6. Pump cement @100 to 125 PSI squeezing cement through perforations into the surrounding formations. (1 sack). When pressure increases, discontinue pumping.				
7. Remove traffic cover, cement flush w/concrete				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____	To _____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From	To	From	To
_____ feet to _____ feet			
_____ feet to _____ feet			

Surface Seal: Yes No Seal Type: Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Location: S of SW corner of fuel tank excavation
 Date started 11-15-95, 19_____
 Date completed 11-15-95, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date November 21, 1995