

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32869
BLDG # 28
14125 MT WASHOE RD

1. OWNER SIERRA NV JOB CORP
 MAILING ADDRESS Box 60009 Reno NV
 ADDRESS AT WELL LOCATION 14125 MT WASHOE RD
 2. LOCATION NE 1/4 SW 1/4 Sec. 29 T. 26 S. R. 19 E. WASHOE County
 PERMIT NO. MB 955 86-143-03
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUSEP

6. LITHOLOGIC LOG MW # 3

| Material | Water Strata | From | To | Thickness |
|--------------------------|--------------|-----------|--------------|-----------|
| <u>CLAY</u> | | <u>0</u> | <u>5</u> | <u>5</u> |
| <u>SILTY CLAY</u> | | <u>5</u> | <u>10</u> | <u>5</u> |
| <u>SILTY CLAY</u> | <u>15</u> | <u>10</u> | <u>15</u> | <u>5</u> |
| <u>FINE-COARSE SANDS</u> | | <u>20</u> | <u>35</u> | <u>15</u> |
| | | | <u>TOTAL</u> | <u>35</u> |

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4</u> | <u>S&H 40</u> | <u>PVC</u> | <u>0</u> | <u>35</u> |

 Perforations:
 Type perforation FACULTY
 Size perforation 1.020
 From 10 feet to 35 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 8 _____ Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 35 feet

RECEIVED
 SEP 20 AM 11:27
 STATE ENGINEERS OFFICE

Date started 7-13 1995
 Date completed 7-13 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature 62.0 °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 Belford Rd Reno NV, 89509
 Nevada contractor's license number 34525 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Andrew Dilling
 By driller performing actual drilling on site or contractor
 Date 8/18/95