

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32869

1. OWNER SIEPPA NW ADDRESS AT WELL LOCATION 14125 MT LOMA ST
 MAILING ADDRESS BOX 60009 RENO NV

2. LOCATION N E 1/4 S4 1/4 Sec 29 T 21 N/S R 19 E WASHOE County
 PERMIT NO. MO 955 86-143-03 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other..... Municipal/Industrial Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other Auger

6. LITHOLOGIC LOG NW # 2

Material	Water Strata	From	To	Thick-ness
<u>LIGHT CLAY</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>FINE SANDS</u>		<u>15</u>	<u>30</u>	<u>10</u>
<u>COARSE SANDS</u>		<u>30</u>	<u>35</u>	<u>5</u>
				<u>WITH 35'</u>

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" To 35"
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>8.18 LB</u>	<u>1/2"</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation FALLOUT
 Size perforation 1.020
 From 10' feet to 35' feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 8' feet to 35' feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow 2.7 G.P.M. 2.4 P.S.I.
 Water temperature 66.5 °F Quality 2.4

Date started 7-14 1995
 Date completed 7-14 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Anderson Drilling Contractor
 Address 1635 BOLEFORD RD Contractor
RENO NV, 89509
 Nevada contractor's license number 34525
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1028
 Division of Water Resources the on-site driller
 Signed Paul Anderson
 By driller performing actual drilling on site or contractor
 Date 8/18/95

RECEIVED
 25 SEP 20 AM 11:27
 STATE ENGINEERS OFFICE