

+

#2 MW-07

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 50332
Permit No.
Basin.

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 054 19940

1. OWNER APark Petroleum ADDRESS AT WELL LOCATION Crescent Valley Market, Crescent Valley Nevada
MAILING ADDRESS PO Box 2877 Eiko NV 89801
2. LOCATION NE 1/4 SW 1/4 Sec 5 T 29 N 1/4 R 48 E Eureka County
PERMIT NO. 19940 M10998 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Air Other ODEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SILT SAND GRAVEL</u>		<u>0</u>	<u>27</u>	<u>8"</u>
<u>CLAY SAND GRAVEL</u>		<u>27</u>	<u>87</u>	<u>8"</u>
<u>CLAY SAND GRAVEL SILTY</u>		<u>87</u>	<u>107</u>	<u>8"</u>
<u>CLAY SAND GRAVEL WET</u>		<u>110'</u>	<u>120</u>	<u>8"</u>

WATER DIDN'T SHOW UP IN DRILLING.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet
HOLE DIAMETER (BIT SIZE)
From To
8" Inches 0 Feet 120 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>0.40</u>	<u>0</u>	<u>80</u>

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.20
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 2 TO 75 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured Concrete Grout
Gravel Packed: Yes No 0-2' SARKRETE FM PROTECT
From 78 feet to 120 feet 75-78' BENTONITE

9. WATER LEVEL
Static water level.....feet below land surface
Artesian flow.....G.P.M.....P.S.I.
Water temperature.....°F Quality.....

Date started DECEMBER 13, 1995
Date completed DECEMBER 18, 1995

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	Draw Down (Feet Below Static)	Time (Hours)
<u>3'x10' BAKER GAL. BAILED G.P.M.</u>				<u>118'</u>	<u>1 1/2 HOURS</u>
					<u>TOOK 15 MIN. TO RECHARGE</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PC Exploration, Inc Contractor
Address 1125 W 650 N Centerville, UT 84014 Contractor
Nevada contractor's license number issued by the State Contractor's Board 95-7301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1605
Signed Ray F. Rosen By driller performing actual drilling on site or contractor
Date 12-22-95

RECEIVED
25 DEC 27 PM 2:43
STATE ENGINEER'S OFFICE