WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50361
Permit No.
Basin 047

NOTICE OF INTENT NO. 31169

1. OWNER Burt Gurr
MAILING ADDRESS 345 5th Street
Elko, NV 89801

ADDRESS AT WELL LOCATION Rockland Dr.
2 mile north of Elko, NV

2. LOCATION NE ¼ NW ¼ Sec. 7 T 34 N/S R 55 E Elko County
PERMIT NO. (Issued by Water Resources) 06-098-39-9 (Parcel No.) Special Lands (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Soil & boulders | | 0 | 12 | 12 |
| Siltstone & boulders | | 12 | 60 | 48 |
| Brown siltstone | | 60 | 170 | 110 |
| Brown siltstone & grave | | 170 | 260 | 90 |
| Brown siltstone | X | 260 | 500 | 240 |

RECEIVED 96 DEC 25 PM 2:46 STATE ENGINEER'S OFFICE

Date started 12-13, 1995
Date completed 12-14, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 4 |

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 5/8 | 0 | 500 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1½ | 500 |
| | | | | |
| | | | | |

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 480 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 410 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Dave Hackworth (By driller performing actual drilling on site or contractor)
Date 12-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627