

OFFICE USE ONLY
 Log No. 50372
 Permit No. 049
 Basin. 049

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32858

1. OWNER US BANK ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 801 IDAHO STREET
ELIHO NEV.
 2. LOCATION SE 1/4 N/E 1/4 Sec. 15 T. 34 N. R. 55 E. ELIHO County
 PERMIT NO. M10 922A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG MW #4

Material	Water Strata	From	To	Thick-ness
<u>SANDS - N - GRAVELS</u>		<u>0</u>	<u>1'</u>	<u>1'</u>
<u>SANDY CLAY</u>		<u>1'</u>	<u>18'</u>	<u>17'</u>
<u>CLAY - N - GRAVEL</u>		<u>18'</u>	<u>21'</u>	<u>3'</u>
<u>SANDY GRAVELS</u>	<u>25'</u>	<u>21'</u>	<u>25'</u>	<u>4'</u>
<u>SANDY CLAY</u>		<u>25'</u>	<u>35'</u>	<u>10'</u>

8. WELL CONSTRUCTION
 Depth Drilled 35' Feet Depth Cased 35' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" To 35"
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>SC11 40</u>	<u>PVC</u>	<u>0'</u>	<u>35'</u>

Perforations:
 Type perforation FACTORY
 Size perforation .020
 From 20' feet to 35' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 15' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 35' feet to 15' feet

RECEIVED
 05 SEP 20 11:28
 STATE ENGINEERING OFFICE

Date started 5, 17, 19, 95
 Date completed 5, 17, 19, 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 25' feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature COLD °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 BELFORD RD. RENO NV 89509
 Nevada contractor's license number 34525 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources 1028 the on-site driller.
 Signed Andrew Dilling
 By driller performing actual drilling on site or contractor
 Date 7/7/95