

Test Hole #1

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 50376  
Permit No. 61196-61212  
Basin 040

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3105

1. OWNER City of Winnemucca ADDRESS AT WELL LOCATION 1/2 mile SE of Lowry High School  
MAILING ADDRESS 90 W. 4th Street  
Winnemucca, NV 89445

2. LOCATION SW 1/4 SW 1/4 Sec. 22 T. 36 (N) S. R. 35 38 E Humboldt County  
PERMIT NO. 61148T-61196-61212  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Test

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel w/boulders & clay		0	50	50
Boulders, Sand, gravel w/some clay		50	150	100
Clay w/gravel		150	225	75
Clay w/boulders some gravel		225	400	175
Yellow sandy clay-dense		400	430	30
Boulders & faulted rock		430	475	40
Brown clay w/gravel & boulders		475	600	125
This hole will be abandoned later. Abandonment log will be sent at that time.				

8. WELL CONSTRUCTION  
Depth Drilled 600 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)  
From 0 Feet To 600 Feet  
6 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:  
Type perforation N/A  
Size perforation \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 20 \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 155 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started September 11, 1995  
Date completed September 15, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	N/A		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co Inc. Contractor  
Address P. O. Box 590 Contractor  
Winnemucca, NV 89446

Nevada contractor's license number issued by the State Contractor's Board 015234  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1195

Signed C.C. Epler By driller performing actual drilling on site or contractor  
Date 12-5-95