

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 50377 & 50378
Permit No. _____
Basin 062
NOTICE OF INTENT NO. 29506

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION NW 1/4 SE 1/4 Sec. 33 T. 36 N. S. R. 47 E. LANDER County
PERMIT NO. M/O-983 N/A Parcel No. N/A Subdivision Name N/A
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------------------|--------------|------|------|-----------|
| ALLUVIAL GRAVEL | TRACE | 0 | 200 | 200 |
| BROWN ROCK | 15 GPM | 200 | 460 | 260 |
| GRAY ROCK WITH CLAYS | 200 GPM | 460 | 740 | 280 |
| GRAY ROCK | 250 GPM | 740 | 1100 | 360 |
| BROWN ROCK | 250 GPM | 1100 | 1460 | 360 |
| GRAY ROCK | 250 GPM | 1460 | 1510 | 50 |

8. WELL CONSTRUCTION
Depth Drilled 1510 Feet Depth Cased 1500 Feet

HOLE DIAMETER (BIT SIZE)
From To
14-3/4 Inches 0 Feet 200 Feet
8 Inches 200 Feet 540 Feet
7-7/8 Inches 540 Feet 1510 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 | 22.36 | .250 | +3 | 200 |
| 2 | 1.5 | SCH 40 | +1 | 380 |
| 2 | 1.5 | SCH 40 | +1 | 1460 |

Perforations:
Type perforation SLOTTED
Size perforation .040
From 380 feet to 420 feet
From 1460 feet to 1500 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 200 Cement Grout
Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
From 370, 1450 feet to 430, 1510 feet

Date started OCTOBER 2 19 95
Date completed OCTOBER 14 19 95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |

9. WATER LEVEL
Static water level #1 108' #2 980' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 65 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1809

Signed BENJIE STOFLET *Benjie Stoflet*
By driller performing actual drilling on site or contractor
Date OCTOBER 26, 1995

RECEIVED
95 NOV -2 AM 11:42
STATE ENGINEERS OFFICE