WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50379
Permit No.
Basin 061

NOTICE OF INTENT NO. 29631

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 36 N/S R. 50 E EUREKA County
PERMIT NO. 61248T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY, SAND, GRAVEL,		0		
CARLIN FORMATION			310	310
SANDSTONE, LIMESTONE		310		
& CALCITE CLAY			770	460
MUDSTONE, SOME		770		
FRACTURES WITH CLAY			1080	310
LIMESTONE, SOME		1080		
FRACTURES			1420	340

Date started OCTOBER 24, 19 95
Date completed OCTOBER 31, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,420 Feet Depth Cased 1,411 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches	0 Feet	75 Feet
19 Inches	75 Feet	1,420 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	95	.375	0	75
12	30.5	.250	0	90

Perforations:
Type perforation LOUVERED SLOT
Size perforation .256
From 90 feet to 1,411 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 75
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 1,420 feet

9. WATER LEVEL
Static water level 544 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 84 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed MARK WAITE Mark Waite
By driller performing actual drilling on site or contractor

Date NOVEMBER 14, 1995

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627