WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PPW-76
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56380
Permit No.
Basin 061

NOTICE OF INTENT NO. 28571

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 30 T 36 N/S R 50 E EUREKA County
PERMIT NO. 55150 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN & BLACK ROCK		0	130	130
GRAY ROCK		130	320	190
GRAY ROCK, CLAY		320	330	10
GRAY ROCK		330	440	110
GRAY & BLACK ROCK		440	650	210
GRAY ROCK		650	715	65
GRAY & BLACK ROCK		715	725	10
GRAY ROCK		725	760	35
BLACK ROCK		760	800	140
BLACK & GRAY ROCK		800	895	95
GRAY CLAY & BLACK ROCK		895	910	15
BLACK & GRAY ROCK		910	950	40
GRAY ROCK, SOME CLAY		950	985	35
GRAY ROCK		985	990	5
GRAY ROCK		990	995	5
GRAY ROCK		995	1010	15

Date started NOVEMBER 14, 19 95
Date completed NOVEMBER 22, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,010 Feet Depth Cased 1,000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches	0 Feet	40 Feet	
13 Inches	40 Feet	887 Feet	
12-1/4 Inches	887 Feet	1,010 Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14			0	40
8			0	60

Perforations:
Type perforation LOUVERED - FULLFLOW
Size perforation
From 60 feet to 1,000 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 1,010 feet

9. WATER LEVEL
Static water level 664 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed VICTOR HERNANDEZ Victor Hernandez
By driller performing actual drilling on site or contractor
Date NOVEMBER 14, 1995

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627