


OFFICE USE ONLY
 Log No. 50387
 Permit No. 212
 Basin. 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17376

1. OWNER ANTHONY SELIG ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 23 T 22 N/S R. 60 E CLARK County
 PERMIT NO. # 64886667457176-23-301-014
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ROCKS SAND + CLAY.</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>SANDSTONE</u>		<u>40</u>	<u>360</u>	<u>220</u>
<u>LIMESTONE</u>		<u>360</u>	<u>270</u>	<u>10</u>
<u>SANDSTONE</u>		<u>270</u>	<u>450</u>	<u>180</u>
<u>LIMESTONE</u>		<u>450</u>	<u>480</u>	<u>30</u>
<u>SANDSTONE w/ STRKS RED CLAY</u>	<u>520</u>	<u>480</u>	<u>810</u>	<u>330</u>

8. WELL CONSTRUCTION
 Depth Drilled 810 Feet Depth Cased 807 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 810 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>+1</u>	<u>807</u>

Perforations:
 Type perforation FACTORY SAW.
 Size perforation 1 7/8 x 2 1/2
 From 767 feet to 787 feet
 From 727 feet to 747 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet to 807 feet

9. WATER LEVEL
 Static water level 420 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WATER WELL SERVICES
 Address 6475 GARY AVE LAS VEGAS, NV. 89139
 Nevada contractor's license number issued by the State Contractor's Board 022311
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1966
 Signed Sydney Couch
 By driller performing actual drilling on site or contractor
 Date 1-19-96

Date started 1-10, 1996
 Date completed 1-17, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

