WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50389
Permit No.
Basin 06

NOTICE OF INTENT NO. 15718

1. OWNER Santa Fe Pacific Gold Corp.
MAILING ADDRESS 861 W. 6th Street
Winnemucca, NV 89445
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 13 T 34 N/S R 42 E Humboldt County
PERMIT NO. M/O-975 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	20'	20'
Clays		20	30	10
Chert/Siltstone/Grn. Stone		30	680	650
Intrusive		680	690	10
Chert/Siltstone/Grn. Stone		690	715	25
Sandstone/Siltstone		715	1400	685
Siltstone/Mudstone		1400	1500	100
Neat Cement		0	50	50
Enviroplaug Medeum		50	1128	1178
Sand Pack Screan		1128	1400	272
Hole Caved In		1400	1500	100

Date started 8/24, 1995
Date completed 9/9, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
380	7	5 minutes
500	25	5 minutes
800	46	5 minutes
1000	100	5 minutes
1100	120	5 minutes
1200	150	5 minutes
1400	150	5 minutes

8. WELL CONSTRUCTION
Depth Drilled 1500' Feet Depth Cased 1400' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	20 Feet
6 Inches	20 Feet	900 Feet
5 3/4 Inches	900 Feet	1500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		3/16 Wall	+2	20
2 1/2		SCH 80 PVC	+2	1400

Perforations:
Type perforation Horz
Size perforation ~~.010 Horz~~ slots
From 1380 feet to 1780 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1400 feet to 1128 feet

9. WATER LEVEL
Static water level 380 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 90 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address P. O. Box 2786 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Lines (By driller performing actual drilling on site or contractor)
Date 9-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627