

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32570

1. **OWNER:** ENVIROS INC  
**MAILING ADDRESS:** P.O. BOX 259  
 Sonoma, CA 94576-0259

**Owner:** ADDRESS AT WELL LOCATION: CHEVRON STATION 0-0735  
 700 No. Sierra Street  
 Reno, Nevada

2. **LOCATION:** A 1/4 1/4 Sec. 4 T. 19N N/S R. 19 E. Washoe County  
**PERMIT NO.:** R-269 WELL VE-2 07-214-24 Reno, Nevada  
M/0-297 Issued by Water Resources Parcel No. Subdivision Name

3. **WORK PERFORMED**  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. **PROPOSED USE**  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. **WELL TYPE**  
 Cable  Rotary  RVC  
 Air  Other.....

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
MONITOR WELL ABANDONMENT:				
Static water level: None				
Total depth: 24.1				
Equipment used: Walnutgrove high pressure cement & pump mixer 20 feet of 3/4 inch Tremie pipe				
Materials used: 10 sacks of Cement Type II w/2% Bentonite				
1.) Measure SWL & TD				
2.) Glue threaded adapter to existing casing.				
3.) Set Tremie pipe to bottom of casing.				
4.) Pump neat cement from bottom to surface.				
5.) Pull Tremie pipe, fill casing & attach from cement pump directly to casing.				
6.) Pump cement @100 to 125 PSI squeezing cement through perforations into the surrounding formations. When pressure increases, discontinue pumping.				
Location: 75 ft. E of N Sierra Street 84 1/2 ft. N of W 7TH Street				

8. **WELL CONSTRUCTION**  
 Depth Drilled.....Feet Depth Cased.....Feet

**HOLE DIAMETER (BIT SIZE)**  
 From To  
 .....Inches.....Feet.....Feet  
 .....Inches.....Feet.....Feet  
 .....Inches.....Feet.....Feet

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation.....  
 Size perforation.....  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal.....  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From.....feet to.....feet

Date started..... 9-27-95 ..... 19.....  
 Date completed..... 9-27-95 ..... 19.....

7. **WELL TEST DATA**

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. **WATER LEVEL**  
 Static water level.....feet below land surface  
 Artesian flow..... G.P.M.....P.S.I.  
 Water temperature.....°F Quality.....

10. **DRILLER'S CERTIFICATION**  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name..... WAYNE DRILLING, INC. Contractor  
 Address..... P.O. BOX 12370 Contractor  
 RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board..... 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 908  
 Signed..... *Avery C. Hedman*  
 By driller performing actual drilling on site or contractor  
 Date..... October 6, 1995