

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27672

1. OWNER Kari Ihria ADDRESS AT WELL LOCATION 7490 Lakeside Drive Reno
MAILING ADDRESS 7490 Lakeside Drive Reno
2. LOCATION SW 1/4 NW 1/4 Sec. 1 T. 19 N. S. R. 19 E. Washoe County
PERMIT NO. 59741 Issued by Water Resources Parcel No. 59741 040-591-19 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Siltstone		0	11	11
Clay, brown, sandy		11	36	25
Clay, brown, silty	L	36	43	7
Clay, brown		43	92	49
Sand		92	96	4
Clay, brown		96	115	19
Gravel, to 3/8"	L	115	123	8
Clay, tan, dark pink		123	147	24
Phyllite	L	147	235	91
Rock, dark grey		235	250	15

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
12 Inches _____ Feet 100 Feet
5.25 Inches 100 Feet 250 Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.97</u>	<u>0.189</u>	<u>0</u>	<u>250</u>

Perforations:
Type perforation factory mill slot
Size perforation 3/32
From 120 feet to 140 feet
From 140 feet to 180 feet
From 180 feet to 210 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100 Cement Grout Concrete Grout
Placement Method: Pumped Poured

Gravel Packed: Yes No
From 100 feet to 250 feet

Date started 9-27-95, 19____
Date completed 9-29-95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u> </u>	<u>4</u>
<u>pumping level 200</u>		

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 64.6 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling Contractor
Address 2790 Pioneer Drive Reno, Nevada 89509 Contractor
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 10/4/95