

OFFICE USE ONLY
 Log No. 50402
 Permit No. 087
 Basin 32173

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32173

1. OWNER Tammel Crow Co. ADDRESS AT WELL LOCATION same as mail add
 MAILING ADDRESS 990 E. Greg St. Sparks, NV 89431
 2. LOCATION SE 1/4 Sec 10 T 19 N R 20 E Washoe County
 PERMIT NO. MO 932 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt concrete		0'	15"	
MED. BROWN SANDY CLAY (CL) some gravel + cobbles		15"	14.5'	
DARK grey silty sand (sm/sp) some gravel		14.5'	25'	
MED. GRAY SILTY SANDY gravel + cobbles (GM)		25'	40'	

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 8" 25" Inches 0 Feet 40 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2"		sch 40	0	15

Perforations:
 Type perforation screen (stainless)
 Size perforation 20
 From 15 feet to 40 feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 4' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4' feet to 40' feet

Date started 5-31 1995
 Date completed 5-31 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 15+- feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name John B. Leisch Contractor
 Address 75 Stewers Creek Rd Carson City NV. 89704 Contractor Nevada Drilling Inc.
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John B. Leisch
 By driller performing actual drilling on site or contractor
 Date 7-10-95