

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28011

1. OWNER JANET AUSTIN ADDRESS AT WELL LOCATION 7605 MOOSE DRIVE
 MAILING ADDRESS 1044 AQUATE AVE MANLECA, CA

2. LOCATION NE 1/4 SE 1/4 Sec. 10 T. 35 S. R. 37 E Humboldt County
 PERMIT NO. 14-24-10 Parcel No. GRASS VALLEY RANCHOS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>clay</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>*clay/little gravel</u>	<u>X</u>	<u>20</u>	<u>60</u>	<u>40</u>
<u>SANDY/gravel</u>		<u>60</u>	<u>90</u>	<u>30</u>
<u>gravel</u>	<u>X</u>	<u>90</u>	<u>110</u>	<u>30</u>
<u>Red clay</u>		<u>110</u>	<u>140</u>	<u>30</u>
<u>gravel/NO CLAY</u>	<u>X</u>	<u>140</u>	<u>150</u>	<u>10</u>

* WATER WAS FOUND AT THIS depth, but very red & HAS A bad taste - so went deeper.

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 150
10 5/8 Inches 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1 8/8</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Factory Cuts
 Size perforation 3/32
 From 90 feet to 110 feet
 From 140 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 56
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 56 feet to 150 feet

Date started 9-20, 1995
 Date completed 9-22, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>N/A</u>	<u>1 hr.</u>

9. WATER LEVEL
 Static water level 42 feet below land surface
 Artesian flow NO G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 GRASS VLY Contractor
MANLECA, NV
 Nevada contractor's license number issued by the State Contractor's Board. 0021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1375
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-5-95